

DOCUMENTATION

REF. CV-41 / WM95

MASK ULTRA PROTECTION FFP2

MASCARILLA ULTRA PROTECCIÓN FFP2

MASQUE FFP2 ULTRA PROTECTION FFP2

MASCHERINA PROTEZIONE ULTRA FFP2



MASTER BOX: 1000 pcs



CV-41

ITEM: WM95

DESCRIPTION: NAAMIO

MATERIAL:

3 PLY (40% non woven, 30% Meltblown, 30% algodón).

QUANTITY: 1.000

G.W

N.W

CNT SIZE

BATCH NUMBER:

PRODUCTION DATE:

VALIDITY:

SUPPLIER NUMBER:

MADE IN P.R.C.

BOX: 25 pcs

L138xW138xH100mm

FFP2
Personal Protective Equipment (PPE)
Equipo de Protección Individual (EPI)

EN 149:2001+A1:2009
FFP2 NR

Filtration Efficiency ≥ 94%



CV-41 MASCARILLA ULTRA PROTECCIÓN FFP2
Comfortable protection against infection / Protección cómoda contra infecciones.

MASCARILLA ULTRA PROTECCIÓN FFP2
Personal Protective Equipment (PPE)
Equipo de Protección Individual (EPI)

Instructions:



Step for usage:

1. Open the foldable mask.
2. Make the nose bridge bar on the up side.
3. Put the strap onto the ear.
4. Adjust the soft bar to fit the nose.
5. Make sure you can breathe well and readjust if necessary.

INSTRUCCIONES DE USO:

1. Abra la máscara plegable.
2. Ajuste la máscara en la parte superior de la nariz.
3. Ajuste las cintas elásticas por detrás de las orejas.
4. Amóde la pizca nasal a la parte superior de la nariz.
5. Asegúrese de poder respirar bien y ajuste si es necesario.

WARNING:

This mask marked "NR" is for single use only. This mask helps protect against certain particulate contaminants but does not completely eliminate exposure to the risk of contracting disease or infection. Change the mask immediately if breathing becomes difficult or the mask becomes damaged or distorted.

ATENCIÓN:

Esta máscara "NR" es recomendada para un solo uso. Esta máscara ayuda a proteger contra ciertas partículas contaminantes, pero no elimina por completo la exposición al riesgo de contraer enfermedades o infecciones. Cambie la máscara inmediatamente si la respiración se vuelve difícil o la máscara se daña o se distorsiona.

FFP2
Personal Protective Equipment (PPE)
Equipo de Protección Individual (EPI)

EN 149:2001+A1:2009
FFP2 NR

Filtration Efficiency ≥ 94%



CV-41 MASCARILLA ULTRA PROTECCIÓN FFP2
Comfortable protection against infection / Protección cómoda contra infecciones.

Description: Mascarilla ultra protección FFP2
Regulation: 2016/425
Personal Protective Equipment (PPE)
EN 149:2001+A1:2009

Organismo notificado: 0370
LGA Technological Center, S.A. (APPLUS)
Calle de Lluís Boniferré 14, Torredembarja, 08713
Bellaterra - Barcelona (Spain)

Product model: WM95
Material: Non-woven fabric 40%,
Meltblown fabric 30%, hot air cotton 30%
Production quantity: 25 pieces/box
Production date: 25/07/2024
Production batch: KZ20240701
Expiry date: 25/07/2027

Conditions of use: **Uso:**
Temperature: 20°C to 40°C, relative humidity less than 80%.
This mask is intended for use against certain particulate contaminants, but does not completely eliminate exposure to the risk of contracting disease or infection. Pay attention to the prevention, maintenance, and proper disposal of the mask.

Storage conditions:
Temperature: 20°C to 40°C, relative humidity less than 80%.
Products in storage and transport should be guaranteed to be sealed, not damaged, not contaminated, not deformed and must pay attention to the prevention, maintenance, and proper disposal of the mask.

Importador por / imported by:
BIBBIBBIBB, S.L. (Spain), S.C.
P.O. Box: 30630, 30633 Cartagena (Spain)

Comprobación certificados/ Certificate verification:
www.certificados.cifra.es

Made in P.R.C.

BAG: 1 pc

133x133 mm

Regulación/ Regulation: 2016/425

FFP2

MASCARILLA ULTRA PROTECCIÓN
ULTRA PROTECTION MASK

Equipo de Protección Individual (EPI)
Personal Protective Equipment (PPE)

Model: WM95

EN 149:2001+A1:2009
FFP2 NR

Filtration Efficiency ≥ 94%



Importado por / Imported by:
BIBBIBBIBB, S.L. (Spain), S.C.
P.O. Box: 30630, 30633 Cartagena (Spain)

Organismo notificado / Notified body:
LGA Technological Center, S.A. (APPLUS)
Calle de Lluís Boniferré 14, Torredembarja, 08713
Bellaterra - Barcelona (Spain)

MADE IN P.R.C.

Comprobación certificados/
Certificate verification:
www.certificados.cifra.es



INSTRUCCIONES DE USO:

1. Abra la máscara plegable.
2. Ajuste la máscara en la parte superior de la nariz.
3. Ajuste las cintas elásticas por detrás de las orejas.
4. Amóde la pizca nasal a la parte superior de la nariz.
5. Asegúrese de poder respirar bien y ajuste si es necesario.

ATENCIÓN:

1. Esta máscara "NR" es recomendada para un solo uso.
2. Esta máscara ayuda a proteger contra ciertas partículas contaminantes, pero no elimina por completo la exposición al riesgo de contraer enfermedades o infecciones.
3. Cambie la máscara inmediatamente si la respiración se vuelve difícil o la máscara se daña o se distorsiona.

MATERIAL:
40% Non-woven, 30% Meltblown, 30% algodón



Mantener a temperatura de 20°C a 40°C / Temperature: 20°C to 40°C

Mantener a Max. humedad relativa: <80% / Relative humidity less than 80%

5 Capas de protección / 5 Layer protection

Equilibrio respiratorio / Equilibrium respiratory

Conversión normal EN 149:2009 / Conversion normal EN 149:2009

Proveer FFP2s / Provide FFP2s

Fecha de producción/ Production date: 25/07/2024
Lote/ Production Batch: KZ20240701
Plazo de validez/ Expiration date: 25/07/2027

4 436534 314702



NOTA IMPORTANTE:

En todos los procesos de fabricación de nuestras mascarillas, no se utiliza grafeno o derivados del mismo.

Colaboramos con



Reconocimiento a la responsabilidad ambiental



Universidad Politécnica de Cartagena



UCAM UNIVERSIDAD CATÓLICA DE MURCIA

UIMP Cartagena
Universidad Internacional Menéndez Pelayo



Asociaciones y Entidades a las que pertenecemos



EU DECLARE OF THE CONFORMITY

We

Company name:	Xiamen Miaoxing Technology Co.,Ltd
Postal address:	5Floor, No.333-4TongFuRoad, TongAn district, Xiamen, China

Declare that the Doc is issued under our sole responsibility and belongs to the following products:

Apparatus model/Product:	WM95
Type:	Filtering half mask

Object of the declaration (identification of apparatus allowing traceability. It includes a color image of sufficient clarity for the identification of the appearance)



The object of the declaration described above is in conformity with the relevant Union harmonization legislation:

Personal protective equipment Regulation (EU)2016/425

The following harmonized standards and technical specifications have been applied: Title,

Date of standards/specification:

PPE-R/02.075 version 1 Filtering half mask to protect against COVID-19

Notified body where applicable

4 digit notified body number

LGAI TECHNOLOGICAL CENTER, S. A./Applus	0370
CERTIFICATE NUMBER:	0370-4376-PPE/B
TECHNICAL REPORT NUMBERED:	PTC20111805301C.EN01

Name and Function of the undersigned	LIU SENMEI / CEO
Signature and Stamp	
Place and Date	2024.9.18

Xiamen Miaoxing Technology Co.,Ltd

5Floor, No.333-4TongFuRoad, TongAn district, Xiamen, China

STATEMENT

Production name: Particle Filtering Half Mask

Model: WM95

Batch reference: KZ2024701

Standard: EN 149:2001+A1:2009

Classification: FFP2 NR.

We declare that masks (customer reference CV-41) have not used graphene and derivatives in the materials and production as we have made laboratory test to proof that.

Name and Function of the undersigned	LIU SENMEI / CEO
Signature and Stamp	
Place and Date	2024.9.18

CERTIFICADO DE EXAMEN UE DE TIPO EU-TYPE EXAMINATION CERTIFICATE



Notified Body No. 0370



No. **0370- 4376-PPE/B**

ORGANISMO NOTIFICADO N° <i>NOTIFIED BODY NUMBER</i>	0370 - LGAI TECHNOLOGICAL CENTER (APPLUS)
SOLICITANTE <i>APPLICANT</i>	Xiamen Miaoxing Technology Co.,Ltd 5Floor,No.333-4TongFuRoad,TongAn district ,Xiamen ,China
FABRICANTE <i>MANUFACTURER</i>	Xiamen Miaoxing Technology Co.,Ltd 5Floor,No.333-4TongFuRoad,TongAn district ,Xiamen ,China
REGLAMENTO DE APLICACIÓN PARA DAR LA CONFORMIDAD APPLICABLE REGULATION TO GIVE CONFORMITY: REGLAMENTO (UE) 2016/425 SOBRE LOS EQUIPOS DE PROTECCIÓN INDIVIDUAL <i>REGULATION (EU) 2016/425 PERSONAL PROTECTIVE EQUIPMENT</i>	
PROCEDIMIENTO DE EVALUACIÓN DE LA CONFORMIDAD <i>CONFORMITY ASSESSMENT PROCEDURE</i>	Módulo // <i>Module</i> : B EXAMEN UE DE TIPO EU TYPE EXAMINATION
IDENTIFICACIÓN DEL EPI (NÚMERO DE TIPO) <i>IDENTIFICATION OF THE PPE (TYPE NUMBER)</i>	Ref.: WM95 Filtering half mask
NIVEL O NIVELES DE RENDIMIENTO O LA CLASE DE PROTECCIÓN DEL EPI PERFORMANCE LEVEL OR PROTECTION CLASS OF THE PPE	FFP2 NR
NORMAS ARMONIZADAS HARMONISED STANDARDS	EN 149:2001 + A1:2009 Dispositivos de protección respiratoria. Medias máscaras filtrantes de protección contra partículas. Requisitos, ensayos, marcado. <i>EN 149:2001 + A1:2009 Respiratory protective devices. Filtering half masks to protect against particles. Requirements, testing, marking</i>
FECHA DE EMISIÓN ISSUE DATE	10/09/2020
FECHA DE MODIFICACIÓN MODIFICATION DATE	01/12/2020
VALIDEZ HASTA VALIDITY UNTIL	10/09/2025
<p>El presente certificado se mantendrá vigente durante 5 años siempre que el producto descrito no sea modificado y cumpla los requisitos esenciales de salud y seguridad establecidos en el Reglamento (UE) 2016/425. Para asegurar dicho cumplimiento, este certificado deberá ir acompañado de la documentación correspondiente a la Evaluación de Conformidad con el tipo según módulo C2, D (realizada por un Organismo Notificado, según frecuencia establecida).</p> <p><i>This certificate will remain valid for 5 years as long as the indicated product is not modified and fulfills the essential requirements of health and safety established in (EU) Regulation 2016/425. To ensure such compliance, this certificate must be accompanied by the documentation corresponding to the Conformity Assessment to type according to C2, D(carried out by a Notified Body according, to the established frequency).</i></p>	


LGAI Technological Center, S.A.
Xavier Ruiz Peña

Managing Director, Product Conformity B.U.



Este documento carece de validez sin su anexo técnico, cuyo número coincide con el del certificado.

This document is not valid without its technical annex, whose number coincides with the number of certificate.

Puede comprobarse la validez de este certificado en nuestra página web / *You can check the validity of this certificate into our website at:*
www.appluslaboratories.com/certified_products

ANEXO TÉCNICO
TECHNICAL ANNEX

0370-4376-PPE/B

I. MODELOS INCLUIDOS EN EL CERTIFICADO

REFERENCES INCLUDED IN THIS CERTIFICATE

MARCA <i>BRAND</i>	MYS
IDENTIFICACIÓN DEL EPI (NÚMERO DE TIPO) <i>IDENTIFICATION OF THE PPE (TYPE NUMBER)</i>	Ref.: WM95 Filtering half mask
NIVEL O NIVELES DE RENDIMIENTO O LA CLASE DE PROTECCIÓN DEL EPI <i>PERFORMANCE LEVEL OR PROTECTION CLASS OF THE PPE</i>	FFP2 NR
INFORME DE ENSAYO <i>TEST REPORT</i>	PTC20111805301C.EN01 issued by Precise Testing & Certification (Guangdong) Co.,Ltd.(PTC)

CERTIFICADO DE CONFORMIDAD CON EL TIPO CONFORMITY TO TYPE CERTIFICATE

LGAI Technological Center, S.A. (APPLUS)
Organismo Notificado / *Notified Body* Nr. 0370

No.

0370-7258-PPE/C2

SOLICITANTE / FABRICANTE <i>APPLICANT / MANUFACTURER</i>	Xiamen Miaoxing Technology Co.,Ltd 5Floor, No.333-4TongFuRoad, TongAn district, Xiamen, China
PLANTA DE PRODUCCIÓN <i>PRODUCTION SITE</i>	Xiamen Miaoxing Technology Co.,Ltd 5Floor, No.333-4TongFuRoad, TongAn district, Xiamen, China
REGLAMENTO DE APLICACIÓN PARA DAR LA CONFORMIDAD / APPLICABLE REGULATION TO GIVE CONFORMITY: REGLAMENTO (UE) 2016/425 SOBRE LOS EQUIPOS DE PROTECCIÓN INDIVIDUAL <i>REGULATION (EU) 2016/425 PERSONAL PROTECTIVE EQUIPMENT</i>	
PROCEDIMIENTO DE EVALUACIÓN DE LA CONFORMIDAD CON EL TIPO <i>CONFORMITY ASSESSMENT PROCEDURE TO TYPE</i>	Módulo // <i>Module</i> : C2 BASADA EN EL CONTROL INTERNO DE LA PRODUCCIÓN MÁS EL CONTROL SUPERVISADO DE LOS PRODUCTOS A INTERVALOS ALEATORIOS <i>BASED ON INTERNAL PRODUCTION CONTROL PLUS SUPERVISED CONTROL OF PRODUCTS AT ALEATORY INTERVALS</i>
IDENTIFICACIÓN DEL EPI (NÚMERO DE TIPO) <i>IDENTIFICATION OF THE PPE (TYPE NUMBER)</i>	Ver Anexo Técnico See Technical Annex
NIVEL O NIVELES DE RENDIMIENTO O LA CLASE DE PROTECCIÓN DEL EPI / PERFORMANCE LEVEL OR PROTECTION CLASS OF THE PPE	FFP2 NR
FECHA DE EMISIÓN / ISSUE DATE	13/09/2024
VALIDEZ HASTA / VALIDITY UNTIL:	13/09/2025
El presente certificado se mantendrá vigente durante 1 año siempre que no se modifiquen las condiciones establecidas en el Certificado de Examen UE de Tipo referenciado en el Anexo. <i>This certificate will remain in force for 1 year as long as the conditions established in the EU Type certificate referenced in the annex are not modified.</i>	




LGAI Technological Center, S.A.
Xavier Ruiz Peña

Managing Director, Product Conformity B.U.

Este documento carece de validez sin su anexo técnico, cuyo número coincide con el del certificado.
This document is not valid without its technical annex, whose number coincides with the number of certificate.

Puede comprobarse la validez de este certificado en nuestra página web / *You can check the validity of this certificate on our website:*
www.appluslaboratories.com/certified_products



El fabricante, después de completar la documentación técnica, el procedimiento de evaluación de la conformidad y la declaración UE de conformidad puede colocar el marcado CE bajo su responsabilidad / *The manufacturer, after the completion of the technical documentation, the conformity assessment procedures and the EU Declaration of conformity, may affix the CE Marking under his responsibility.*

ANEXO TÉCNICO TECHNICAL ANNEX

0370-7258-PPE/C2

I. MODELOS INCLUIDOS EN EL CERTIFICADO

REFERENCES INCLUDED IN THIS CERTIFICATE

DATOS GENERALES / GENERAL DETAILS

Nº CERTIFICADO DE EXAMEN UE DE TIPO <i>NR. EU TYPE EXAMINATION CERTIFICATE</i>	0370-4376-PPE/B
EMITIDO POR <i>ISSUED BY</i>	LGAI TECHNOLOGICAL CENTER S.A. (Organismo notificado nº 0370 / Notified Body nr. 0370).
FECHA EMISIÓN <i>ISSUE DATE</i>	10/09/2020
VALIDEZ HASTA <i>VALIDITY UNTIL</i>	10/09/2025
MARCA <i>BRAND</i>	MYS
NIVEL O NIVELES DE RENDIMIENTO O LA CLASE DE PROTECCIÓN DEL EPI / PERFORMANCE LEVEL OR PROTECTION CLASS OF THE PPE	FFP2 NR
DESCRIPCIÓN <i>DESCRIPTION</i>	MEDIA MÁSCARA FILTRANTE SIN VÁLVULA, DE TIPO PLEGABLE VERTICAL, DE 5 CAPAS, CON LAZOS DE OREJA CON GANCHO Y CLIP NASAL INTERIOR. TAMAÑO: 155mm*105mm. VALVELESS FILTERING HALF MASK, VERTICAL FOLDING TYPE, 5 LAYERS, WITH EAR LOOPS WITH HOOK AND INTERIOR NOSE CLIP SIZE: 155mm*105mm
INFORME DE ENSAYO <i>TEST REPORT</i>	S24090204801E issued by Shenzhen NTEK Testing Technology Co., Ltd. (NTEK)

DATOS ESPECIFICOS / SPECIFIC DETAILS

IDENTIFICACIÓN DEL EPI (NÚMERO DE TIPO) <i>IDENTIFICATION OF THE PPE (TYPE NUMBER)</i>	Ref.: WM95 Filtering half mask
COLORES <i>COLOURS</i>	Blanco / White

ANEXO TÉCNICO
TECHNICAL ANNEX

0370-7258-PPE/C2

IDENTIFICACIÓN DEL EPI (NÚMERO DE TIPO) <i>IDENTIFICATION OF THE PPE (TYPE NUMBER)</i>	Ref.: WM95B Filtering half mask
COLORES <i>COLOURS</i>	Negro / Black



中国认可
国际互认
检测
TESTING
CNAS L5772

Test Report

EN 149:2001+A1:2009 protective devices. Filtering half masks to protect against particles. Requirements, testing, marking

Product: Filtering half mask
Report No.: PTC20111805301C-EN01
Client: Xiamen Miaoxing Technology Co.,Ltd
Client Address: 5Floor,No.333-4TongFuRoad,TongAn district ,Xiamen ,China
Manufacturer: Xiamen Miaoxing Technology Co.,Ltd
Manufacturer Address: 5Floor,No.333-4TongFuRoad,TongAn district ,Xiamen ,China
Contact: Mr.Liu
Model(s): WM95
Classification: FFP2 NR
Date of Tests: 2020.11.23~2020.11.27

Signed for and on Behalf of PTC

Prepare by:

Checked by:

Approved by:

Arme

Jue

Jim Mo



This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 2 of 14

Summary of assessment

Clause	Assessment
7.3 Visual inspection	NOT TESTED
7.4 Packaging	PASS
7.5 Material	PASS
7.6 Cleaning and disinfecting	N/A
7.7 Practical performance	PASS
7.8 Finish of parts	PASS
7.9.1 Total inward leakage	PASS
7.9.2 Penetration of filter material	PASS
7.10 Compatibility with skin	PASS
7.11 Flammability	PASS
7.12 Carbon dioxide content of the inhalation air	PASS
7.13 Head harness	PASS
7.14 Field of vision	PASS
7.15 Exhalation valve	N/A
7.16 Breathing resistance	PASS
7.17 Clogging	N/A
7.18 Demountable parts	PASS
9 Marking	NOT TESTED

Remark:

PASS: comply with requirement of standard
N/A: not application
NOT TESTED: the clause were not required

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 3 of 14

Test Result:

Requirement	Test Result	Conclusion
7.3 Visual inspection The visual inspection shall also include the marking and the information supplied by the manufacturer.	Not tested	Not tested
7.4 Packaging Particle filtering half masks shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use.	In accordance with the requirement.	Pass
7.5 Material Materials used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used. Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer. After undergoing the conditioning described in 8.3.1 none of the particle filtering half masks shall have suffered mechanical failure of the facepiece or straps. When conditioned in accordance with 8.3.1 and 8.3.2 the particle filtering half mask shall not collapse.	No mechanical failure after undergoing the conditioning described in 8.3.1, No collapse when conditioned in accordance with 8.3.1 and 8.3.2.	Pass
7.6 Cleaning and disinfecting If the particle filtering half mask is designed to be re-usable, the materials used shall withstand the cleaning and disinfecting agents and procedures to be specified by the manufacturer.	Single shift use only	N/A
7.7 Practical performance The particle filtering half mask shall undergo practical performance tests under realistic conditions	No imperfections	Pass
7.8 Finish of parts Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs.	No sharp edges or burrs.	Pass

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 4 of 14

7.9.1 Total inward leakage

For particle filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual exercise results (i.e. 10 subjects x 5 exercises) for total inward leakage shall be not greater than 25 % for FFP1, 11 % for FFP2, 5 % for FFP3

FFP2, Test results are shown in Annex A Table 7.9.1-A&B **Pass**

and, in addition, at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall be not greater than 22 % for FFP1, 8 % for FFP2, 2 % for FFP3.

7.9.2 Penetration of filter material

The penetration of the filter of the particle filtering half mask shall meet the requirements of Table 1.

	Sodium chloride test 95 l/min	Paraffin oil test 95 l/min
FFP1	≤ 20%	≤ 20%
FFP2	≤ 6%	≤ 6%
FFP3	≤ 1%	≤ 1%

FFP2, Test results are shown in Annex A Table 7.9.2. **Pass**

7.10 Compatibility with skin

Materials that may come into contact with the wearer's skin shall not be known to be likely to cause irritation or any other adverse effect to health.

No irritation or any other adverse effect to health. **Pass**

7.11 Flammability

When tested, the particle filtering half mask shall not burn or not to continue to burn for more than 5 s after removal from the flame.

Test results are shown in Annex A Table 7.11. **Pass**

7.12 Carbon dioxide content of the inhalation air

The carbon dioxide content of the inhalation air (dead space) shall not exceed an average of 1,0 % (by volume)

Test results are shown in Annex A Table 7.12. **Pass**

7.13 Head harness

The head harness shall be designed so that the particle filtering half mask can be donned and removed easily.

Head harness can be donned and removed easily, adjustable or self-adjusting and **Pass**

The head harness shall be adjustable or self-adjusting and shall be

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted. The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 http:// www.ptc-testing.com



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 5 of 14

sufficiently robust to hold the particle filtering half mask firmly in position and be capable of maintaining total inward leakage requirements for the device.

have sufficiently robust to hold the particle filtering half mask firmly.

7.14 Field of vision

The field of vision is acceptable if determined so in practical performance tests.

Pass the practical performance tests.

Pass

7.15 Exhalation valve

A particle filtering half mask may have one or more exhalation valve(s), which shall function correctly in all orientations.

If an exhalation valve is provided it shall be protected against or be resistant to dirt and mechanical damage and may be shrouded or may include any other device that may be necessary for the particle filtering half mask to comply with 7.9.

No exhalation valve

N/A

Exhalation valve(s), if fitted, shall continue to operate correctly after a continuous exhalation flow of 300 l/min over a period of 30 s.

When the exhalation valve housing is attached to the faceblank, it shall withstand axially a tensile force of 10 N applied for 10 s.

7.16 Breathing resistance

Classification	Maximum permitted resistance (mbar)		
	Inhalation		Exhalation
	30 l/min	95 l/min	160 l/min
FFP1	0.6	2.1	3.0
FFP2	0.7	2.4	3.0
FFP3	1.0	3.0	3.0

FFP2. Test results are shown in Annex A Table 7.16.

Pass

7.17 Clogging

7.17.2 Breathing resistance

Valved particle filtering half masks:

After clogging the inhalation resistances shall not exceed:

FFP1: 4 mbar, FFP2: 5 mbar, FFP3: 7 mbar at 95L/min continuous flow

The exhalation resistance shall not exceed 3 mbar at 160 L/min

Single shift use only.

N/A

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted. The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 http:// www.ptc-testing.com



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 6 of 14

continuous flow

Valveless particle filtering half masks

After clogging the inhalation and exhalation resistances shall not exceed:

FFP1: 3 mbar, FFP2: 4 mbar, FFP3: 5 mbar at 95L/min continuous flow

7.17.3 Penetration of filter material

	Sodium chloride test 95 l/min	Paraffin oil test 95 l/min
FFP1	≤ 20%	≤ 20%
FFP2	≤ 6%	≤ 6%
FFP3	≤ 1%	≤ 1%

7.18 Demountable parts

All demountable parts (if fitted) shall be readily connected and secured, where possible by hand

Comply

Pass

9 Marking

9.1 Packaging

The following information shall be clearly and durably marked on the smallest commercially available packaging or legible through it if the packaging is transparent.

9.1.1 The name, trademark or other means of identification of the manufacturer or supplier.

9.1.2 Type-identifying marking.

9.1.3 Classification

The appropriate class (FFP1, FFP2 or FFP3) followed by a single space and then: "NR" if the particle filtering half mask is limited to single shift use only. Example: FFP3 NR, or "R" if the particle filtering half mask is re-usable.

Not tested

Not tested

Example: FFP2 R D.

9.1.4 The number and year of publication of this European Standard.

9.1.5 At least the year of end of shelf life. The end of shelf life may be informed by a pictogram as shown in Figure 12a, where yyyy/mm indicates the year and month.

9.1.6 The sentence 'see information supplied by the manufacturer', at least in the official language(s) of the country of destination, or by using

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted. The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 http:// www.ptc-testing.com



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 7 of 14

the pictogram as shown in Figure 12b.

9.1.7 The manufacturer's recommended conditions of storage (at least the temperature and humidity) or equivalent pictogram, as shown in Figures 12c and 12d.

9.1.8 The packaging of those particle filtering half masks passing the dolomite clogging test shall be additionally marked with the letter "D". This letter shall follow the classification marking preceded by a single space.

9.2 Particle filtering half mask

Particle filtering half masks complying with this European Standard shall be clearly and durably marked with the following:

9.2.1 The name, trademark or other means of identification of the manufacturer or supplier.

9.2.2 Type-identifying marking.

9.2.3 The number and year of publication of this European Standard.

9.2.4 Classification

The appropriate class (FFP1, FFP2 or FFP3) followed by a single space and then: "NR" if the particle filtering half mask is limited to single shift use only. Example: FFP3 NR, or "R" if the particle filtering half mask is re-usable. Example: FFP2 R D.

9.2.5 If appropriate the letter D (dolomite) in accordance with clogging performance. This letter shall follow the classification marking preceded by a single space.

9.2.6 Sub-assemblies and components with considerable bearing on safety shall be marked so that they can be identified.

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 8 of 14

Annex A: Summarization of Test Data

Table 7.9.1-A: Inward Leakage Test Data

Test specification: EN 149:2001+A1:2009 Clause 8.5

Subject	Sample No.	Condition	Walk (%)	Head Side/side (%)	Head up/down (%)	Talk (%)	Walk (%)	Mean (%)
Lv	1	A.R	4.3	5.0	5.6	6.6	7.4	5.8
Li	2	A.R	3.4	4.3	5.3	5.9	5.1	4.8
Zhong	3	A.R	5.4	6.4	7.2	7.5	5.6	6.4
Xu	4	A.R	4.6	3.5	4.5	5.7	5.9	4.8
Ma	5	A.R	5.5	6.1	5.2	5.6	5.3	5.5
Chen	6	T.C	5.9	6.6	5.3	7.4	5.2	6.1
Chen	7	T.C	5.2	5.3	4.7	6.7	4.7	5.3
Zhuo	8	T.C	5.6	6.7	5.2	7.6	8.3	6.7
Chen	9	T.C	5.7	5.2	5.4	5.3	5.9	5.5
Zhang	10	T.C	5.2	5.6	5.0	6.3	4.8	5.4

Table 7.9.1-B: Facial dimension

Subject	Face Length	Face Width	Face Depth	Mouth Width
Lv	113	139	104	53
Li	120	135	112	55
Zhong	108	135	106	56
Xu	120	150	120	70
Ma	130	170	130	80
Chen	110	160	90	40
Chen	115	145	110	50
Zhuo	103	146	100	50
Chen	110	145	95	40
Zhang	144	141	101	54

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 9 of 14

Table 7.9.2: Penetration of filter material

Test specification: EN 149:2001+A1:2009 Clause 8.11

Aerosol	Condition	Sample No.	Penetration (%)	Assessment
Sodium chloride test	As received	11	4.6	Pass
		12	5.6	
		13	5.0	
	Simulated wearing treatment	14	2.4	
		15	4.4	
		16	3.1	
	Mechanical strength + Temperature conditioned	17	4.8	
		18	5.3	
		19	3.8	
Paraffin oil test	As received	20	2.6	
		21	4.9	
		22	5.4	
	Simulated wearing treatment	23	2.1	
		24	3.0	
		25	3.0	
	Mechanical strength + Temperature conditioned	26	3.2	
		27	2.6	
		28	2.9	

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)
Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 10 of 14

Table 7.11: Flammability

Test specification: EN 149:2001+A1:2009 Clause 8.6

Condition	Sample No.	Result	Assessment
As received	29	No burn	Pass
	30	No burn	
Temperature conditioned	31	No burn	
	32	No burn	

Table 7.12: Carbon dioxide content of the inhalation air

Test specification: EN 149:2001+A1:2009 Clause 8.7

Condition	Sample No.	Result (%)		Assessment
As received	33	0.02	Mean value: 0.02	Pass
	34	0.02		
	35	0.02		

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)
Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 11 of 14

Table 7.16: Breathing resistance (mbar)

Test specification: EN 149:2001+A1:2009 Clause 8.9

As received	Flow Rate		36					37					38				
	Inhalation	30 l/min	0.41					0.46					0.43				
		95 l/min	1.74					1.79					1.72				
	Exhalation	160 l/min	A	B	C	D	E	A	B	C	D	E	A	B	C	D	E
2.11			2.07	2.02	2.03	2.02	2.05	2.03	2.04	2.06	2.06	2.07	2.11	2.09	2.07	2.08	
Simulated wearing treatment	Flow Rate		39					40					41				
	Inhalation	30 l/min	0.32					0.30					0.31				
		95 l/min	1.14					1.14					1.15				
	Exhalation	160 l/min	A	B	C	D	E	A	B	C	D	E	A	B	C	D	E
1.94			1.88	1.85	1.87	1.89	1.91	1.93	1.90	1.91	1.91	1.91	1.94	1.89	1.90	1.95	
Temperature conditioned	Flow Rate		42					43					44				
	Inhalation	30 l/min	0.27					0.27					0.28				
		95 l/min	1.05					1.07					1.07				
	Exhalation	160 l/min	A	B	C	D	E	A	B	C	D	E	A	B	C	D	E
1.67			1.71	1.71	1.68	1.71	1.67	1.68	1.69	1.69	1.71	1.70	1.69	1.69	1.69	1.69	
Assessment	Pass																

A: Facing directly ahead B: Facing vertically upwards C: Facing vertically downwards

D: Lying on the left side E: Lying on the right side

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted.
The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)

Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 12 of 14

Test	Uncertainty
Total inward leakage	3.8%
Penetration of filter material(NaCl)	3.5%
Penetration of filter material(Paraffin oil)	4.2%
Carbon dioxide content of the inhalation air	4.5%
Breathing resistance(30L/min)	5.2%
Breathing resistance(95L/min)	5.4%
Breathing resistance(160)L/min)	6.0%

Photo(s) of Sample:



This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted. The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)
Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)




Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 13 of 14



This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted. The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)
Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)



Test Report

Report No.:PTC20111805301C-EN01

Issue Date: Nov.27, 2020

Page 14 of 14



End of Report

This report is issued according to the general clauses in www.ptc-testing.com by PTC. Responsibility, guarantee and law restriction are defined in the general service clauses. The report is only responsible for the submitted sample(s) except as otherwise noted. The report could not be copied without permission

Precise Testing & Certification (Guangdong) Co., Ltd. (PTC)
Building 1, No. 6, Tongxin Road, Dongcheng Street, Dongguan, Guangdong, China.
Tel: 86-769-38808222 Fax: 86-769-38826111 [http:// www.ptc-testing.com](http://www.ptc-testing.com)

Test Report

Applicant: Xiamen Miaoxing Technology Co.,Ltd
Address: 5Floor,No.333-4TongFuRoad,TongAn district ,Xiamen ,China
The following sample(s) was/were submitted and identified on behalf of the client as:
Product name: Filtering half mask
Model: WM95/WM95B
Trade mark: MYS
Manufacturer: Xiamen Miaoxing Technology Co.,Ltd
Address: 5Floor,No.333-4TongFuRoad,TongAn district ,Xiamen ,China
Classification: FFP2 NR
Sample quantity: 70 Pcs
C2 Sampling done by
APPLUS+ with ID 24/32307049
number :
Sample Received Date: Sep. 02, 2024
Testing Period: Sep. 02, 2024~ Sep. 10, 2024

Test Requirement:

According to the requirement of the Module C2 (SPC CE-062_EN M7 PPE) of Applus+, the test item(s) of the sample is according to the standard EN 149:2001+A1:2009.

Test Result(s): Please refer to the following page(s)

Test Method: Please refer to the following page(s)

Compiled by: Zane

Reviewed by: May

Approved by: Aaren

Date: 2024-09-10

Sample list

Sample No.	Model	Description
1#	WM95	White mask
2#	WM95	White mask
3#	WM95	White mask
4#	WM95	White mask
5#	WM95	White mask
6#	WM95	White mask
7#	WM95	White mask
8#	WM95	White mask
9#	WM95	White mask
10#	WM95	White mask
11#	WM95	White mask
12#	WM95	White mask
13#	WM95	White mask
14#	WM95B	Black mask
15#	WM95B	Black mask
16#	WM95B	Black mask
17#	WM95	White mask
18#	WM95	White mask
19#	WM95	White mask
20#	WM95B	Black mask
21#	WM95B	Black mask
22#	WM95B	Black mask
23#	WM95	White mask
24#	WM95	White mask
25#	WM95	White mask
26#	WM95B	Black mask
27#	WM95B	Black mask
28#	WM95B	Black mask
29#	WM95B	Black mask
30#	WM95B	Black mask
31#	WM95B	Black mask
32#	WM95B	Black mask

Sample No.	Model	Description
33#	WM95B	Black mask
34#	WM95B	Black mask
35#	WM95B	Black mask
36#	WM95B	Black mask
37#	WM95B	Black mask

Test Result

Respiratory Protective Devices — Filtering Half Masks to Protect against Particles — Requirements, Testing, Marking
(EN 149:2001+A1:2009)

Clause 7.3 Visual inspection

Test Requirement	Results	Comment
Marking and the information supplied by the manufacturer, requirements refer to clause 9 and clause 10.	Comply	Pass

Clause 7.5 Material

(EN 149:2001+A1:2009, Clause 8.2 & 8.3.1 & 8.3.2)

Test Requirement	Results	Comment
Materials used shall be suitable to withstand handling and wear over the period for which the particle filtering half mask is designed to be used.	Comply	Pass
After undergoing the conditioning described in 8.3.1 none of the particle filtering half masks shall have suffered mechanical failure of the face piece or straps.	Comply	Pass
When conditioned in accordance with 8.3.1 and 8.3.2 the particle filtering half mask shall not collapse.	Comply	Pass
Any material from the filter media released by the air flow through the filter shall not constitute a hazard or nuisance for the wearer.	Comply	Pass

Clause 7.8 Finish of Parts

EN 149:2001+A1:2009, Clause 8.2)

Test Requirement	Results	Comment
Parts of the device likely to come into contact with the wearer shall have no sharp edges or burrs.	No sharp edges or burrs	Pass

Clause 7.9.1 Total Inward Leakage
(EN 149:2001+A1:2009 Clause 8.5)

Test Requirement	Results	Comment
<p>For particle filtering half masks fitted in accordance with the manufacturer's information, at least 46 out of the 50 individual exercise results (i.e. 10 subjects x 5 exercises) for total inward leakage shall be not greater than:</p> <p style="padding-left: 40px;">25% for FFP1 11% for FFP2 5% for FFP3</p> <p>and, in addition, at least 8 out of the 10 individual wearer arithmetic means for the total inward leakage shall be not greater than:</p> <p style="padding-left: 40px;">22% for FFP1 8% for FFP2 2% for FFP3</p>	Detail refer to Appendix 1	Pass

Appendix 1: Summarization of Test Data

Subject	Sample	Condition	Normal Breathing (%)	Head Side/Side (%)	Head Up/Down (%)	Speak Loudly (%)	Normal Breathing (%)	Mean (%)
Zhang	1#	A.R.	4.3	4.4	4.6	4.9	4.2	4.48
Fan	2#	A.R.	5.2	5.3	5.7	5.8	5.0	5.40
Yang	3#	A.R.	4.9	5.1	5.2	5.3	4.9	5.08
Huang	4#	A.R.	5.6	5.9	6.1	6.2	5.8	5.92
Yan	5#	A.R.	6.0	6.1	6.1	6.3	6.2	6.14
Shi	6#	T.C.	5.5	5.6	5.7	5.9	5.4	5.62
Huang	7#	T.C.	4.9	5.0	4.8	5.1	5.3	5.02
Chen	8#	T.C.	5.0	5.5	5.6	5.7	5.1	5.38
Lei	9#	T.C.	4.4	4.6	4.7	4.9	4.6	4.64
Shen	10#	T.C.	4.9	5.1	5.2	5.4	5.2	5.16

Facial Dimension:

Subject	Length of Face (mm)	Width of Face (mm)	Depth of Face (mm)	Width of Mouth (mm)
Zhang	120	175	115	57
Fan	120	155	115	55
Yang	125	165	120	55
Huang	116	187	126	57
Yan	104	163	115	52
Shi	110	144	117	46
Huang	108	136	105	52
Chen	115	135	121	57
Lei	111	137	121	53
Shen	112	138	119	54

Clause 7.9.2 Penetration of Filter Material

(EN 149:2001+A1:2009, Clause 8.11)

Test Requirement			Results	Comment
The penetration of the filter of the particle filtering half mask shall meet the requirements of the following table.			Detail refer to Appendix 2	Pass
Classification	Maximum penetration of test aerosol (%)			
	Sodium chloride test 95 L/min	Paraffin oil test 95 L/min		
FFP1	20	20		
FFP2	6	6		
FFP3	1	1		

Appendix 2: Summarization of Test Data

Penetration of filter material

Aerosol	Condition	Sample No.	Penetration (%)		Assessment
			Average in 30s after 3 min	Max. during exposure	
Sodium chloride test	A.R.	11#	0.01	/	Pass
		12#	0.07	/	
		13#	0.10	/	
	S.W.	17#	0.28	/	
		18#	0.26	/	
		19#	0.29	/	
	M.S. + T.C.	23#	/	1.30	
		24#	/	1.49	
		25#	/	1.42	
	Paraffin oil test	A.R.	14#	0.29	
15#			0.26	/	
16#			0.29	/	
S.W.		20#	0.43	/	
		21#	0.46	/	
		22#	0.47	/	
M.S. + T.C.		26#	/	2.75	
		27#	/	2.74	
		28#	/	2.56	
Flow rate of test aerosol: 95.0 L/min					

Clause 7.16 Breathing Resistance

EN 149:2001+A1:2009, Clause 8.9)

Test Requirement				Results	Comment
The breathing resistances apply to valved and valveless filtering half masks and shall meet the requirements as the following table.				Detail refer to Appendix 3	Pass
Classification	Maximum permitted resistance (mbar)				
	Inhalation		Exhalation		
	30 L/min	95 L/min	160 L/min		
FFP1	0.6	2.1	3.0		
FFP2	0.7	2.4	3.0		
FFP3	1.0	3.0	3.0		

Appendix 3: Summarization of Test Data

Specimen	Condition	Inhalation(mbar)		Exhalation resistance(mbar)				
		At 30 L/min	At 95 L/min	At 160 L/min				
				A	B	C	D	E
29#	A.R.	0.34	1.27	2.12	2.12	2.14	2.13	2.14
30#		0.35	1.28	2.12	2.14	2.13	2.14	2.12
31#		0.35	1.28	2.14	2.13	2.12	2.14	2.13
32#	S.W.	0.37	1.30	2.16	2.16	2.15	2.17	2.16
33#		0.36	1.30	2.17	2.15	2.15	2.16	2.17
34#		0.37	1.29	2.15	2.17	2.16	2.17	2.17
35#	T.C.	0.32	1.24	2.07	2.09	2.09	2.08	2.07
36#		0.33	1.25	2.09	2.08	2.07	2.09	2.08
37#		0.33	1.24	2.09	2.07	2.08	2.07	2.09
/	T.C.+F.C.	/	/	/	/	/	/	/
/		/	/	/	/	/	/	/
/	F.C.	/	/	/	/	/	/	/

A: facing directly ahead; B: facing vertically upwards; C: facing vertically downwards; D: lying on the left side; E: lying on the right side

Clause 7.18 Demountable Parts

(EN 149:2001+A1:2009, Clause 8.2)

Test Requirement	Results	Comment
All demountable parts (if fitted) shall be readily connected and secured, where possible by hand.	Comply	Pass

Sample photo(s):



Fig.1 (Black mask)



Fig.2 (Black mask)



Fig.3 (Black mask)



Fig.4 (Black mask)



Fig.5 (White mask)



Fig.6 (White mask)



Fig.7 (White mask)



Fig.8 (White mask)

****End of Report****

The test report is effective only with both signature and specialized stamp, the result(s) shown in this report refer only to the sample(s) tested. Without written approval of NTEK, this report can't be reproduced except in full; The laboratory is not responsible for the authenticity of the sample information provided by the customer; The laboratory is not responsible for any deviation of results due to methods/standards provided by the customer.